



Hangzhou Easy Electric Wire and Cable Co.,LTD

Add: Room 305, Building 2, No. 380 Fengxin Road, Hangzhou, China

www.eescable.com

TEST REPORT

Products	CABLE DESNUDO DE COBRE		Size	8AWG 7*1.23mm	
Standard	ASTM B3 ASTM B8	Invoice No.	20230907003	Date	2023.09.07
NO.	Item	Standards and Requirements	Test Results	Evaluation	
1	Structure				
1-1	Number Of Wire	7	7	Qualified	
1-2	Dia. Of Wire	1.23±0.0125mm	1.23	Qualified	
1-3	Elongation in 250mm.(min)	≥25%	31%	Qualified	
1-4	20℃Max D.C Resistivity	≤0.017241 Ω · mm ² /m	0.016985	Qualified	
1-5	Diameter Of Conductor	3.69±0.1mm	3.69	Qualified	
1-6	Direction of of the last layer	Rightward	Rightward	Qualified	
2	Surface Of Conductor				
2-1	Surface Quality	The Surface Shall Be Smooth, Stranded Compactly, No Missing, Broken, Jumping or Loosing Strands.	Smooth, Compact	Qualified	
3	Conductor Properties				
3-1	20℃ Max D.C Resistance	≤0.212 Ω /km	0.203	Qualified	
3-2	Approximate total weight of cable	74.9±1.5Kg/km	75.2	Qualified	

Tested by: Shaoqiong He

Checked by Guohui Xu

杭州益睿电线电缆有限公司
HANGZHOU EASY ELECTRIC WIRE AND CABLE CO., LTD.

Hangzhou Easy Electric Wire and Cable Co.,LTD

Add: Room B415, Future Technology Park, No.7 Long Tan Road Hangzhou,China