

निर्माता अनुमोदन / MANUFACTURER APPROVAL

संदर्भ: : CC/QA&I/2021/Letter/591

दिनांक: 01-DEC-

उपरोक्त का नाम/ Name of Proposer			
निर्माता का नाम/ Name of Manufacturer	Hangzhou Easy Electric Wire and Cable Co. Ltd. (EES Cable)		
सी.आई.एन संख्या/ CIN Number	91330110MA28LR0X6W		
निर्माता का पता/ Address of Manufacturer	Room No. B415, Future Technology Park, No. 7, Long Tan Road		
	City: Hangzhou	State/Country: Zhejiang/China	Pin/Zip Code: NA
निर्माता कोड/ Manufacturer Code	NA		
नाम और संपर्क विवरण/ Name & Contact details	Ms Joyce +86-05718616530 JOYCE@EESCABLE.COM		
मद का नाम/ Item Name	Aluminium Cladded Steel Wire for further manufacturing HTLS type ACSS Conductor		
वैधता अवधि/ Validity period up to	Valid for following project only*: Transmission line package for Khetri-Bhiwadi 400 kV D/C line (Twin HTLS) under Transmission scheme for evacuation of Power from solar energy zones in Rajasthan		
Background details: This has reference to your email dated 19.11.2021 vide which you had requested for manufacturer approval of M/s Hangzhou Easy Electric Wire for supply of above items. Based on the request and submission of relevant documents, further virtual assesment was carried out by our representative at above mentioned works on 25.11.2021. On successful compliance of observation points made during assessment, we hereby convey our acceptance of M/s Hangzhou Easy Electric Wire and Cable Co. Ltd. having works addressed as above, for supply of aforementioned item.			

Contractor and Manufacturer shall be fully responsible for satisfactory performance of approved products. Please note that the items supplied shall meet the requirements of POWERGRID Specifications/ Approved Drawing/ Data Sheets/ GTP/MQP, relevant IS standards. Manufacturer shall ensure that the above documents are available at the works so that proper inspection is carried out without delay. If, at any point of time, any abnormality is noticed in this regard, we reserve the right to increase our involvement by way of additional inspection and/or additional customer inspection points (CIP) at any stage or withdraw this approval with immediate effect.

Special Remarks:
Following points are also to be ensured:

1. Ensure that 100% of coils are tested as per POWERGRID TS requirement after the material is received at their works prior to manufacturing the HTLS type ACSS conductor.
2. For the first 02 (two) lots of ACS wire supplied by M/s Hangzhou, stage inspection by POWERGRID shall be carried out having sampling plan of 10%.

Note 1: Letter regarding- Non-Indulgence in Fraudulent / Unethical Practices attached.

**SANJEEV
KUMAR PANDEY**

 Digitally signed by
 SANJEEV KUMAR PANDEY
 Date: 2021.12.01 11:48:34
 +05'30'

संजीव कुमार पांडेय

 वरुण उप महापबंधक (गुं आ० एवं
 नि०)

उचित:

- 1) संधित निरीक्षण
कर्मालय

Enclosure: As above